

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7165-1130:265

Page 1 of 2

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Honeywell International, Inc. 1500 W. Dundee Road, Arlington Heights, IL 60004-1472
Contact: Bob Hodgson (847) 797-4000 ext 4403 FAX (847) 797-3664

DESIGN: Model XLS140-2 fire alarm control unit. Local, auxiliary, remote station (PPU), proprietary (PPU), central station (PPU), manual, automatic, waterflow and sprinkler supervisory services. Also suitable for releasing service. Model numbers may be followed by a "R" suffix representing the enclosure color being red. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

XLS140-CPU2	CPU Board
XLS-NCA-2	Network Communication Annunciator
NCM-W, -F	Network Control Module
LEM-320/XLS-ELEM-320	Loop Expander Module
KDM-R2	Keyboard Display Module
TM-4	Transmitter Module
KAPS-24	Power Supply
CAB-4 Series	Enclosure
DP-1B	Blank Panel
BMP-1	Blank Module
ADP-4B, DP-DISP2	Dress Panels
CHS2-M2	Chassis
BB-100, -200, XLS-LBB/LBBR	Battery Boxes
BP2-4	Battery Dress Plates
RPT-W, -485W	Repeater Wire
RPT-F, -485F	Repeater Fiber
RPT-WF	Repeater Fiber/Wire
SCS-8	Smoke Control Station
SCE-8	Smoke Control Expander
SCS-8L	Smoke Control Lamp Driver Station
SCE-8L	Smoke Control Expander Lamp
FCPS-24S6, -24S8	Field Charger/Power Supply
XPM-8L	Transponder Monitor Modules
XLS-PRN-6	Printer
S464G1007	Addressable Manual Pull Station
NBG-12LRA	Agent Releasing Abort Station
CRT-2	Display Terminal
DPI-232	Panel Interface
RKS-S	Remote Security Key Switch

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL Label

APPROVAL: Listed as fire alarm control units suitable for use in nonhigh-rise applications when used in conjunction with separately listed compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 2002 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: For **Fire Alarm Verification** feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 Seconds.

05-29-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division